

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243996
Address: 3212 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Thursday, January 02, 2025

Informational:
1 Misc 12-23-24 Dustin A, Sw is formed and compacted and slopes are in compliance.
Approved to pour
01-02-24 Jamie S, SW is poured to city specs. The last panel of the sidewalk on the north side has a dip that will retain water. Cannot pass until forms are pulled.

Comments: