CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230994

Address: 1021 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Erosion Control Robb Popp Failed Monday, December

16, 2024

Informational:

1 Misc -Install gravel filter at site entrance and clean mud from streets. No further

inspections will be performed until in compliance

1-2-25 BR Contractor installed gravel on south entrance of site and clean up

mud off street.

Comments: