

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243479
Address: 2817 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Thursday, January 02, 2025

Informational:
1 Misc 01-02-25 Jamie S, SW has been formed and compacted. Gravel on either side was not deep enough to connect to existing sidewalk. Talked to contractor and approved to pour contingent upon fixing the depth of gravel.

Comments: