

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242617  
Address: 2743 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Thursday, January 02, 2025

**Corrective Action Required:**

1	Miscellaneous Correction	12-18-24 DP. Driveway was formed but is saturated with water will need to be dug out or dried out before pour. Make sure to call an inspection back in. FAILED 12-23-24 Dustin A, DW has been dug out to dry conditions. Slopes and aggregate is in compliance. Approved to pour 01-02-25 Jamie S, DW has been poured to city specs. Slopes are in compliance. Cannot pass until forms are pulled.
---	--------------------------	---

**Comments:**