

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244542  
Address: 3215 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, January 02, 2025

Corrective Action Required:

1 Misc

- seal penetration in powder room into furr down
- fireblock hvac chase in pantry
- fire block hvac chase in great room near windows
- fire block stairwell wall to under stair area
- all anchor bolts in basement to be tightened
- provide ridge support at front covered patio
- no gas line installed

**Comments:**