## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20245538 Address: 2770 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Erosion Control		Inspector: Shawn Hoffman	Outcome: Failed	Date: Thursday, January 02, 2025
1	DCM1 ESC	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE		
	REQUIRED NO	PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.		
	FURTHER INSP			
		-POST ADDRESS		
		- PROTECT BACK OF LC	T AROUND SPOILS PILE	

**Comments:**