
DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

January 02, 2025

ROCK CREEK HOMES
6126 METCALF LANE
OVERLAND PARK, KS 66202

Permit No: PRLD20246495
Project Title: WOODLAND GLEN
Project Address: 930 SW SCHERER RD, LEES SUMMIT, MO 64082
Parcel Number: 61920159900000000
Location / Legal: MEETS AND BOUNDS
Description:
Type of Work: Land Disturbance
Occupancy Group: NOT APPLICABLE
Description: WOODLAND GLEN - REMOVE TO PONDS AND ASSOCIATED GRADING

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By:

Approved

ESC Application and Plan Review

Reviewed By: Sue Pyles, P.E.

Corrections

1. Please include foam silt dike and inlet protection standard details and submit the SWPPP.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.