

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245263
Address: 2626 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Friday, January 03, 2025

Corrective Action Required:

1 Misc

Corrective Action Required:

2 Misc

1-3-24 Dustin A, Dw is formed. Aggregate is not compacted and is too shallow. Will need dug out and have min 4 inch of gravel. Recall when corrected for another inspection

Comments: