

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243955  
Address: 3141 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, January 03, 2025

Corrective Action Required:

1 Misc

-strap top plate lapped less than 24" above home office window (strap shall extend 6" past plate break)  
-provide full bearing for beam in basement at beam pick center rear garage(lumber being used in contact with concrete shall be treated and secure)

OKAY TO INSULATE

**Comments:**