

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Friday, January 03, 2025

Informational:

1	Misc	8-29-24 DA. Met with Andrew with summit, went over some trip hazards that were in the SW that needs to be fixed.
		9-16-24 Dustin A, SW hazards have been fixed. ADA warning pad has not been replaced. Cannot sign off until that and street sign is replaced.
		1-3-24 Dustin A, SW has passed

Comments: