

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242943  
Address: 2778 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Devon Perry	Passed	Friday, January 03, 2025

Informational:

1	Misc	11-12-24 DP. DW was formed, aggregate compacted, mentioned to keep the cross slopes in compliance across the DW since this lot gets SW. Approved to pour.
		1-3-25 DP. DW was poured, forms removed, cross slopes are in compliance. Passed

**Comments:**