

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Ready for Temp CO	Friday, January 03, 2025

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Label RTUs-Use permanent labels -Seal penetrations at riser room-Missing at water line -Remove trash from rooftop
---	------	---

Comments: