

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081
Inspected On: Monday, January 06, 2025
Inspected By: Development Center
Expiration Date: 1/3/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Ready for Temp CO	Friday, January 03, 2025

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Label RTUs-Use permanent labels -Seal penetrations at riser room-Missing at water line -Remove trash from rooftop
---	------	---

Occupancy Inspection - Codes Commercial	Robb Popp	Ready for Temp CO	Wednesday, December 04, 2024
--	-----------	-------------------	---------------------------------

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Label RTUs-Use permanent labels -Label Hoods per LSFD -Seal penetrations at riser room-Missing at water line -Remove trash from rooftop
---	------	--

Comments: