

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241136
Address: 3237 SW ARBOR TREE DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, January 07, 2025
Inspected By: Development Center
Expiration Date: 1/3/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, September 12, 2024

Corrective Action Required:

1	Misc	-pay all fees -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -identify sewer tracer wire -will check water meter at time of final grade and sod
---	------	--

Comments: