



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115556, Building Permit - Commercial
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Tuesday, November 15, 2011

Partial Correction
1 MISC

OK TO POUR WHEN READY PER DETAIL 03/S2.2 FOUR ADDITIONS TO EXISTING FOOTINGS AT NAVE SOUTH; PER A/E REVISION, TWO FOOTING ADDITIONS AT BAPTISTRY CORNERS PER 03/S2.2 IN LIEU OF BEAM PER 04/S2.2;

Comments: