

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243024
Address: 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Tuesday, January 07, 2025

Corrective Action Required:

1	Misc	Premises identification is still incorrect. Fix before re inspection
		Re establish correct premises identification
		-seal penetrations in RA joist space above master bath/walk in
		-fireblock top of hvac chase at master shower
		-address multiple holes throughout entire home drilled in joists closer than 2" to one another
		-fireblock great room slider wall to ceiling space
		-provide rafter to ceiling joist connection throughout 2nd floor
		-seal penetrations in vertical to horizontal fire blocking in basement
		-seal penetrations in RA joist space in basement

Comments: