

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244542
Address: 3215 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Tuesday, January 07, 2025

Corrective Action Required:

1	Misc	-fire block hvac chase in great room near windows -fire block stairwell wall to under -all anchor bolts in basement to be tightened -provide ridge support at front covered patio
---	------	--

Comments: