

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243302
Address: 1808 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, December 12, 2024

Corrective Action Required:

1	Misc	- Pay all fees - Address pending sidewalk inspection - Obtain an irrigation permit and submit a back flow certificate - Raise water meter pit to grade with meter height at 14-18" from lid
---	------	--

Comments: