



December 30, 2024

KC Concrete

Re: 1430/32 SW Winthrop Terrace  
Lot 51, Woodland Glen  
Lee's Summit Permit #: PRRES20242859

Apex Engineers, Inc. observed the preparation for the garage slabs at the above-referenced addresses.

The garage slabs will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved prints.

Note:

- The inspection was performed at 9:45 am
- At the time of the inspection the temperature was 40°F.
- Erosion control was in place at the time of the inspection.

Our firm recommends approval of the garage slabs for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

---

#### LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

A handwritten signature in black ink, appearing to read 'Nick A. Shifflett'.

Nick Shifflett, E.I.T.  
Field Engineer

Clayton J. Hess, P.E.  
Principal

