

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241046

Address: 1427 SW WINTHROP TER, LEES SUMMIT, MO 64081
1425 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Thursday, January 09, 2025

Corrective Action Required:

1	Misc	BOTH 1425-1427
		- Uncover water meter for inspection
		- Land sewer trace wire at grade
		- Final grading and sod
		- installation of irrigation system
		- pending driveway and sidewalk inspections

Comments: