

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242625
Address: 1633 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 09, 2025

Corrective Action Required:

1	Misc	16633 sw arborway ter
		<ul style="list-style-type: none">- final grading and sod- Uncover water meter for inspection- Check plot plan- Provide gutters and downspouts- Provide splash pads- Sup discharge to be 36" away from foundation- Pending driveway inspection

Comments: