

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242625
Address: 1633 SW ARBORWAY TER, LEES SUMMIT, MO 64082
Inspected On: Thursday, January 09, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 09, 2025

Corrective Action Required:

1	Misc	16633 sw arborway ter
		<ul style="list-style-type: none">- final grading and sod- Uncover water meter for inspection- Check plot plan- Provide gutters and downspouts- Provide splash pads- Sup discharge to be 36" away from foundation- Pending driveway inspection

Comments: