

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20243640
Address: 500 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Thursday, January 09, 2025

Corrective Action Required:

1	Misc	-Support all mc off of grid -Provide support wires at opposite corners of all 2x4 lights -Connect bath exhaust -Install knockout cover at j box above prep
---	------	---

Comments: