

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Thursday, January 09, 2025

Corrective Action Required:

1 Misc

Upper floor:

-All except guest suite, restrooms, work/break room, leasing office

Basement:

-Correct rated wall deficiencies as discussed

****Support and securely fasten all NM cables per code**

Comments: