

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241762
Address: 2805 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, January 10, 2025

Corrective Action Required:

1 Misc

- uncover covered water meter for inspection
- outlet at outdoor fireplace to be gfci protected
- water heater relief valve piping to close to floor
- provide box extenders at basement wet bar island backsplash.

Comments: