

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245370
Address: 2737 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Friday, January 10, 2025

Informational:

1 Misc

Above-ceiling OK:
-X-ray and control room

Corrective Action Required:

2 Misc

Protect penetrations of stair enclosure; label above-ceiling fire-rated wall per code

Comments: