

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242598  
Address: 3808 SW RAVENGATE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Ready for Temp CO	Monday, January 13, 2025

Corrective Action Required:

2	Miscellaneous Correction	- Final grading and sod - Land sewer trace wire at grade - Provide splash pads at down spouts
---	--------------------------	---

City requested a TCO extension form and builder replied

TCO extended until 02/10/25

**Comments:**