

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244404  
Address: 3207 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, January 13, 2025

Corrective Action Required:

2	Misc	-fireblock rear garage wall into furr down -fire block right and left of great room windows (chases) -complete bath vents -install missing roof boots -fire block penetrations top plate master bed exterior wall -strap top plate bed 2 where lapped less than 24" -bond gas line.
---	------	---

Comments: