

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242860

Address: 1438 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1436 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Kyle Beard	Failed	Monday, January 13, 2025

Corrective Action Required:

1	Miscellaneous Correction	Gas failed on both sides because of no pressure in the system at the time of inspection
---	--------------------------	---

**Comments:**