

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242275  
Address: 630 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Failed	Wednesday, January 15, 2025

Informational:

1	Miscellaneous Correction	- Exterior sheathing inspection only. Passed and is okay to cover *Inspection behind cooler walls location: -Install bocca plate at vent, tighten hold down device
---	--------------------------	--

**Comments:**