



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115524, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	John Borns	Partial	Thursday, November 17, 2011
Partial Correction 1 MISC		PIER INSTALLATION MONITORED BY S.E.A. AND PSI; PER EARLIER DISCUSSION W/ G.C. CITY INSPECTIONS WAIVED ON DEEP DRILLED PIERS ONLY	
Footing Inspection - Commercial	John Borns	Not Ready	Thursday, November 17, 2011
Corrective Action Required 1 MISC		NOTED 11/17/2011 THAT ELEVATOR PIT SLAB WAS POURED WITHOUT CITY INSPECTION.	
Corrective Action Required 2 MISC		CAUTIONED G.C. 11/17/2011 THAT ALL RE-BAR INCLUDING MATS AND CAGES MUST HAVE FULL 3" CLEARANCE TO BOTTOMS & BANKS PER ACI AND APPROVED PROJECT DRAWINGS.	

Comments: