

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241045

Address: 1433 SW WINTHROP TER, LEES SUMMIT, MO 64081
1431 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, January 15, 2025

Corrective Action Required:

1	Miscellaneous Correction	Unit 1433 needs the sump pump receptable to state it is non GFCI protected
---	--------------------------	--

Both units

- Exterior could not be verified due to snow on the ground
- Plot plan needs to pass

Unit 1431 passed for TCO only

This is a partial list only becausew of the ground conditions

Comments: