

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241833
Address: 2147 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, January 15, 2025

Corrective Action Required:

2	Miscellaneous Correction	-sod -splash blocks and sump pump discharge to extend 36" from foundation -uncover covered water meter for inspection -identify sewer tracer wire and land in locator box -address pending driveway and sidewalk inspection -obtain issued lawn irrigation permit
---	--------------------------	--

Passed for TCO only

Comments: