

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244364  
Address: 1050 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, January 15, 2025

Corrective Action Required:

1	Misc	- (4) #4 vertical bars not present - Remove water from piers - no thermal protection for 20 degree weather
---	------	--

**Comments:**