

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242369  
Address: 1617 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Wednesday, January 15, 2025

Corrective Action Required:

1	Misc	TCO EXTENSION GRANTED FOR ANOTHER 30days. 01/15/25
		-address to be properly illuminated
		-final grade and sod
		-splash blocks and sump pump discharge to extend 36" from foundation
		-bring water meter pit to grade (ensure 14"-18" from top of meter to well lid ring)
		-identify sewer tracer wire

Comments: