

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216391
Address: 2040 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, January 15, 2025

Informational:

1	Misc	HOME HAS NOT HAD INSPECTIONS FOR BASEMENT FINISH, PERMIT AND INSPECTIONS SHALL BE REQUIRED PRIOR TO FINISHING BASEMENT.
---	------	---

Corrective Action Required:

2	Misc	-lockout for water heater breaker -gfc protection for outlets under kitchen sink
---	------	---

Comments: