



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20115441
Address: 910 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086
Inspected On: Thursday, November 17, 2011
Inspected By: John BornsJoe DirJoe DirJoe Dir
Expiration Date: 12/1/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|------------------|--------------------------------|
| Occupancy Inspection - Codes Commercial | John Borns | Temporary C of O | Thursday, November 17, 2011 |

Corrective Action Required:

1 MISC RESTROOMS: FLOORS TO BE FINISHED NON-ABSORBENT
AND FREE OF JOINTS/CRACKS; BASE TO BE INSTALLED

Corrective Action Required:

2 MISC FLOOR SINK: COMPLETE CAULK JOINT AT WALL

Corrective Action Required:

3 MISC WATER HEATER: INSTALL E.T. PER DRWG; RAISE TO
FACILITATE FULL DRAIN TO FLOOR SINK; ENSURE TPR PIPE
TERMINATES NO MORE THAN 6" AFF

Corrective Action Required:

4 MISC PERMANENT TAG GAS SERVICE 910 M

Corrective Action Required:

5 MISC IN-USE COVER REQUIRED AT RTU ELECTRICAL
RECEPTACLE

Corrective Action Required:

| | | | | |
|--------------------------------|------|---|--------|--------------------------------|
| 6 | MISC | EXTERIOR LIGHTED SIGN MUST BE MANUFACTURED BY UL CERTIFIED COMPANY AND BE LABELED ACCORDINGLY. | | |
| Alarm Test | | Joe Dir | Passed | Thursday, November 17, 2011 |
| Sprinkler - Flow Test | | Joe Dir | Passed | Thursday, November 17, 2011 |
| Occupancy Inspection - Fire | | Joe Dir | Passed | Thursday, November 17, 2011 |

Comments: