

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 16, 2025

Corrective Action Required:
1 Misc TCO EXTENSION GRANTED FOR ANOTHER 30DAYS.

- address pending sidewalk inspection
- final grade and sod
- provide as graded plot plan
- splash blocks and sump pump discharge to extend 36" from foundation

Comments: