

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, January 16, 2025
Inspected By: Development Center
Expiration Date: 2/24/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 16, 2025

Corrective Action Required:

1	Misc	TCO EXTENSION GRANTED FOR ANOTHER 30DAYS.
---	------	---

- address pending sidewalk inspection
- final grade and sod
- provide as graded plot plan
- splash blocks and sump pump discharge to extend 36" from foundation

Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Tuesday, December 24, 2024
---	---------------	-------------------	----------------------------

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -final grade and sod -provide as graded plot plan -splash blocks and sump pump discharge to extend 36" from foundation
---	------	--

Comments: