

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242858

Address: 1426 SW WINTHROP TER, LEES SUMMIT, MO 64081
1424 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Thursday, January 16, 2025

Informational:

1	MISC	Attic fire separation wall and basement floor joist-OK
---	------	--

****Make sure to firecaulk wall membrane penetration at ridge**

Comments: