

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242860

Address: 1438 SW WINTHROP TER, LEES SUMMIT, MO 64081
1436 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Thursday, January 16, 2025

Corrective Action Required:

2	Miscellaneous Correction	1436 - gas pressure gauge goes up to 200PSI - replace gas gauge with a pressure limit no more than 35 PSI
		1438 gas passed

Comments: