

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243018
Address: 1905 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, January 16, 2025

Corrective Action Required:

2	Miscellaneous Correction	Back porch stair risers are at 7 inches, 7 inches and at the top of the threshold is only 6 inches
		Stair raiser height by code can not vary by more than 3/8 of an inch
		Pay \$75fee associated with this permit

Comments: