CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20242381Address:2213 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, January 16, 2025

Corrective Action Required:

1 Miscellaneous Correction	 Fire block gap above interior overhead garage doors at ceiling Garage to house steps need a guard rail installed Kitchen hood vent is not installed Receptacle covers missing throughout Remove smoke dust covers throughout Utility room attic access hatch is missing Bottom stair landing to the basement does not have the required 36 inches of travel distance Basement refrigerator receptacle needs to be GFCI protected Vent fan in basement bathroom is not installed Guard rail is needed on front porch west side Outside AC unit is not installed Seal gap in siding to foundation wall along the east side Front porch soffit is not complete Sod, splash pads and sump pump extension are not installed Plot plan could not be completed due to snow on the ground Sidewalk inspection must pass
-------------------------------	--

Comments: