

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, January 17, 2025

Corrective Action Required:

1 Misc

Pre final for units only
***Building C

4th floor units and corridor approved

3rd floor:

1328-Provide GFCI protection at peninsula and wall receptacle

IDF: Seal all penetrations, firetape ceiling and walls

2nd floor:

1221 - sprinkler head painted above bathroom door

MEP-Install smoke seals at door, seal all penetrations

1st floor:

Install cover at clean out in corridor, install all smoke seals at all doors,
remove plastic and all construction items from corridor past firewall for
egress path in area D ALL FLOORS

IDF-Complete condensate line, smoke seals at door

Comments: