



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115441, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Monday, November 21, 2011

Corrective Action Required
6 MISC

EXTERIOR LIGHTED SIGN MUST BE MANUFACTURED BY UL
CERTIFIED COMPANY AND BE LABELED ACCORDINGLY.

Comments: CALL WHEN SIGN IS INSTALLED. IF UL LABELS WILL BE ON TOPS OF SIGN
ELEMENTS CALL IN ADVANCE FOR INSPECTION.