

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245058  
Address: 2606 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, January 21, 2025

Corrective Action Required:

1 Misc Fb = fire blocking or draft stop

- Add stud under double 2x12 at stairs wall and mud hall
- Fb gap at top plate fur out south side where plumbing above
- All 10' vertical fire blocking seal electrical penetrations
- Protect electrical in studs at basement rear bed door
- Fb top of double wall at basement tub
- anchor bolts to be in the middle 1/3 of sill plate

**Comments:**