

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243024
Address: 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|---------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Tuesday, January 21, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -multiple holes throughout entire home drilled in joists closer than 2" to one another(all holes not address provide engineer report for fix uploaded to portal and onsite) |
|---|------|---|

Comments: