

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242860

Address: 1438 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1436 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, January 22, 2025

Corrective Action Required:

2	Miscellaneous	1436
	Correction	- gas pressure read 1 PSI at time of inspection
		1438 gas passed

**Comments:**