

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242672
Address: 1020 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, January 22, 2025

Corrective Action Required:

1	Misc	-Complete corrections for LSFD -Obtain Jackson County Health Department approval -Provide backflow devices for ice machine and carbonated beverage machines -Provide proper air gap at drains to floor -Sinks in restrooms not to be above 34" -Mirrors in restrooms to be max 40" to reflective surface -Provide GFCI protection at all kitchen receptacles
---	------	--

Comments: