

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, January 22, 2025

Corrective Action Required:

1	FIRST FLOOR	*****AREAS APPROVED TO COVER: -Entry canopy ok to cover Additon complete except as noted -Clean room at existing tie in 1E 169. Address penetrations and incomplete rated assembly **Existing side: 02-1E153 & Materials Management 02-1E152 1E202A thru 1E202I, 1E203, 1E204 thru 1E209, Corridor 1E200D, 1E200E, 1E223, 1E226 Hard lids at: 1E-227, 1E228, 1E229,1E130, 1E131
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR	Above-ceiling OK below: **Addition Complete except at existing south stair: label fire wall
---	--------------	--

**Existing side
2E423, 2E421, 2E422, 2E420, 2E242, 2E241,2E200J, 2E240, 2E238, 2E239

Corrective Action Required:

3	THIRD FLOOR	**Addition complete
---	-------------	---------------------

Comments: